

Skylake Fire Hydrants

In addition to the annual inspection, maintenance and testing performed by Skylake staff, the Emergency Preparedness Committee (EPC) conducts periodic supporting maintenance to each of the 71 fire hydrant sites.

An EPC Team will visit each fire hydrant location and address any weeds, overgrowth, and accessibility to each hydrant. It is important that during an emergency that the fire department has clear and unobstructed access to the hydrant. The EPC Team will also fix a reflective tape strip to the hydrant bonnet. This enables the fire department to identify the location of the hydrant at night.

Tasks Performed

1. Clear and clean the immediate area near and around each fire hydrant by cutting any weeds or trimming any overgrowth.
2. Spray weed killer around a three (3) foot radius from each hydrant.
3. Install / replace reflective tape on each fire hydrant bonnet.
4. Report any damage or concerns to the Skylake POA Office.

Complete the EPC inspection report and forward it to the POA Office.

